



LANCASTER FIRE DEPARTMENT KNOX BOX INFORMATION



- Knox Boxes are required on all Commercial Buildings in accordance with the 2012 International Fire Code
- Every Fire Alarm System will require a Knox box.
- All Knox Boxes must be approved by the Fire Marshal.
- Every Fire Sprinkler System will require two Knox Boxes; one near the front door and one at the Fire Sprinkler Riser Room.

Purchasing a Knox Box:

- Knox Boxes are available for purchase at the Lancaster Public Safety Building.
 - 1650 N. Dallas Ave., Lancaster, TX 75134
- Please call 972-218-2600 for pricing
- Acceptable for of payment:
 - Checks- Made payable to Knox Company
 - Money Orders- Made Payable to Knox Company
 - Credit Card
- You may purchase a Knox Box online
 - www.knoxbox.com

Choose: TEXAS

Type: LANCASTER

Click here and enter all applicable information.

We use Model # 3202

Knox Box Installation information:

- Must be located to the right side of the front door.
- Must be installed at a height no greater than 5 feet and no lower than 4 feet from the ground.